

CERTIFICATE OF COMPLIANCE

Certificate Number 20170809-R26797
Report Reference R26797-20160429
Issue Date 2017-AUGUST-09

Issued to: SALTO SYSTEMS S L
POL. LANBARREN. ARKOTZ 9
20180 OIARTZUN SPAIN

This is to certify that
representative samples of

ELECTRICALLY CONTROLLED SINGLE-POINT LOCKS
AND LATCHES

Salto Ci25xx and Ci26xx Series electrically controlled single point lock of the cylindrical type with a XS4 Mini Series Reader Assembly. These lock sets may be provided with 1/2 in. (13 mm) latchbolt for cylindrical type locks. For use on doors rated 45 minutes.

Salto Ti25xx and Ti26xx Series electrically controlled single point lock of the tubular type with a XS4 Mini Series Reader Assembly. These lock sets may be provided with 9/16 in. (14.2 mm) latchbolt for tubular type locks. For use on doors rated 45 minutes.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10C, Positive Pressure of Fire Tests of Door Assemblies
ANSI/UL 10B, Fire Tests of Door Assemblies
CAN/ULC-S104-15, Standard Method for Fire Tests of Door Assemblies

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

