

CERTIFICATE OF COMPLIANCE

Certificate Number R26942
Report Reference R26942-20190930
Issue Date 2020-JANUARY-10

Issued to: SALTO SYSTEMS S L
POL. LANBARREN. ARKOTZ 9 20180 OIARTZUN SPAIN

This certificate confirms that
representative samples of

ACCESSORIES FOR SINGLE-POINT LOCKS AND
LATCHES AND FIRE-EXIT HARDWARE

Accessories for Single-point Locks and Latches and Fire-exit Hardware, model SALTO NEO electronic cylinder Nixx, for installation with Salto LA1T mortise lock or any other UL Certified mortised lock designed to accept a removable key cylinder with a diameter of 1.15 in. -32UNS for use in swinging type fire doors rated up to and including 3 hours.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: ANSI/UL 10C, Positive Pressure Fire Tests of Door Assemblies
ANSI/UL 10B, Fire Tests of Door Assemblies
CAN/ULC-S104-15, Standard Method for Fire Tests of Door Assemblies

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

